

## Integrated adsorption-ORC system:

Al-Mousawi, Fadhel; Al-Dadah, Raya; Mahmoud, Saad

DOI:

[10.1016/j.applthermaleng.2016.12.069](https://doi.org/10.1016/j.applthermaleng.2016.12.069)

License:

Creative Commons: Attribution-NonCommercial-NoDerivs (CC BY-NC-ND)

*Document Version*

Peer reviewed version

*Citation for published version (Harvard):*

Al-Mousawi, F, Al-Dadah, R & Mahmoud, S 2017, 'Integrated adsorption-ORC system: Comparative study of four scenarios to generate cooling and power simultaneously', *Applied Thermal Engineering*, vol. 114, pp. 1038-1052. <https://doi.org/10.1016/j.applthermaleng.2016.12.069>

[Link to publication on Research at Birmingham portal](#)

### **Publisher Rights Statement:**

Checked 6/1/2017

### **General rights**

Unless a licence is specified above, all rights (including copyright and moral rights) in this document are retained by the authors and/or the copyright holders. The express permission of the copyright holder must be obtained for any use of this material other than for purposes permitted by law.

- Users may freely distribute the URL that is used to identify this publication.
- Users may download and/or print one copy of the publication from the University of Birmingham research portal for the purpose of private study or non-commercial research.
- User may use extracts from the document in line with the concept of 'fair dealing' under the Copyright, Designs and Patents Act 1988 (?)
- Users may not further distribute the material nor use it for the purposes of commercial gain.

Where a licence is displayed above, please note the terms and conditions of the licence govern your use of this document.

When citing, please reference the published version.

### **Take down policy**

While the University of Birmingham exercises care and attention in making items available there are rare occasions when an item has been uploaded in error or has been deemed to be commercially or otherwise sensitive.

If you believe that this is the case for this document, please contact [UBIRA@lists.bham.ac.uk](mailto:UBIRA@lists.bham.ac.uk) providing details and we will remove access to the work immediately and investigate.

# Integrated adsorption-ORC system: Comparative study of four scenarios to generate cooling and power simultaneously

Fadhel Noraldeen Al-Mousawi<sup>a,b\*</sup>, Raya Al-Dadah<sup>a</sup>, Saad Mahmoud<sup>a</sup>

<sup>a</sup> Department of Mechanical Engineering, University of Birmingham, United Kingdom, B15 2TT, United Kingdom

<sup>b</sup> Department of Mechanical Engineering, University of Karbala, Karbala, Iraq

\*e-mail address: fna397@bham.ac.uk (fadhelnor@gmail.com)

## Abstract

Adsorption cooling and Organic Rankine Cycle (ORC) systems are promising technologies that can be used to exploit the abundant amount of low grade heat sources such as solar energy, geothermal energy and waste heat from industrial processes. In this study, a two bed adsorption cooling cycle has been integrated with an ORC to simultaneously generate cooling and power utilising AQSOA-ZO2 (SAPO-34)/water and silica-gel/water as adsorption working pairs and R245fa, R365mfc and R141b as ORC working fluids. Four different scenarios of integrated adsorption-ORC system have been investigated, where in the first three scenarios, adsorption system is set up as a topping system, while ORC is set up as a bottoming system. The first one utilized the waste heat of adsorption to power the ORC system with no additional heat and named as Adsorption Heat Recovery Scenario (AHRS). In the second scenario the adsorption return heating fluid is used to power the ORC system (Return Adsorption Heating Fluid Scenario RAHFS). In the third scenario (Heat Exchanger Scenario HES), the cooling and heating sources leaving the adsorption system enter a heat exchanger, where additional heat can be added to the cooling fluid in order to power the ORC system. In the fourth scenario (Return ORC Heating Fluid Scenario RORCHFS), the ORC is considered to be as a topping system, while the adsorption system considered as bottoming system and the return ORC heating fluid can be used to power the adsorption cycle. Results show that when using AHRS, the integrated adsorption -ORC system can achieved system efficiency of 70% using silica-gel/water and R141b and 60% using SAPO-34/water and R141b. In addition, the maximum Specific Power (SP) and Specific Cooling Power (SCP) can be achieved utilising SAPO-34 and R141b with values of 208 W/kg<sub>ads</sub> and 616 W/kg<sub>ads</sub> respectively. This work highlights the potential of using integrated adsorption cooling system and ORC to generate cooling and power simultaneously.

**Keywords** Adsorption, ORC, Cooling and power generation, AQSOA-ZO2 (SAPO-34), Silica-gel

## Nomenclature

### Symbols

A	adsorption potential, J/mole
$A_r$	area, m <sup>2</sup>
$c_p$	specific heat capacity, J/kg.K
$k_o$	empirical constant in Eq. (6), 1/s
$E_a$	activation energy, J/kg
H	enthalpy, J/kg
$H_{fg}$	evaporation latent heat J/kg
M	mass, kg
$\dot{m}$	mass flow rate, kg/s
P	pressure, Pa
$Q_{st}$	isosteric heat of adsorption, J/kg
R	gas constant, J/kg.K
$R_p$	adsorbent practice radius, m
U	overall heat transfer coeff., W/m <sup>2</sup> K
W	power generated W
SP	specific power generated W/kg <sub>ads</sub>
SCP	specific cooling power W/kg <sub>ads</sub>
t	time, s
T	temperature, K
x	adsorption uptake, kg/kg <sub>ads</sub>
$x_{eq}$	equilibrium uptake, kg/kg <sub>ads</sub>

$\rho$  density kg/m<sup>3</sup>

$\varphi$  flag

### Subscript

ads,a	adsorbent
ads	adsorption
bed	adsorbent bed
chill	chilled water
des	desorption
eff	effective
evap	evaporator
f	liquid
g	gas
i	adsorption/desorption
in	inlet
j	cooling / heating source
o	outlet
ref	refrigerant
r	ratio
s	saturation
cond	condenser
w	water

31 **1. Introduction**

32 As population has grown significantly during last century, millions of people who live in developing  
 33 countries still lack to access to secure electricity grids and the problem becomes worse in hot  
 34 countries where a large amount of power is needed for air conditioning. In addition, using  
 35 conventional fossil fuels has a negative impact on the environment issue such as global warming and  
 36 the climate change which pushed more research towards a real change in the energy policy [1].  
 37 Organic Rankine cycle (ORC) used in a range of applications, including industrial waste heat  
 38 recovery [2], solar thermal [3], biomass power plants [4], and geothermal [5]. Table (1) demonstrates  
 39 a number literature using ORC with a range of working fluids and heat source temperatures.

**Table 1: Organic Rankine cycle (ORC).**

Author	Working fluid	Evap. Temp. °C	ORC type	Results
Le et al [6]	R134a, R152a R32, R744, R1270, R290, R1234yf, R1234ze(E)	150	Supercritical (basic and regenerative)	Max efficiency of 13.1% using R152a
Pei et al [7]	R-123	120	Regenerative	Max efficiency of 8.6%, 9.2% higher than basic efficiency
Mago et al [8]	R113, R245ca, R123, and isobutane	100-210	Regenerative	Higher first and second efficiencies than basic efficiency and lower irreversibility
Aljundi [9]	12 refrigerants	50-140	Basic with heat exchanger	Max efficiency of 13.36% using neo-Pentane
Tchanche et al [10]	20 refrigerants	60-100	Solar with heat storage	R134a appears as the most suitable for small scale solar applications
Roy et al [11]	R12, HCFC-123, HFC-134a, R717	277 (heat source)	non-regenerative	R-123 produces the maximum efficiencies and output with minimum irreversibility

40 Absorption and adsorption cooling systems utilising low grade heat sources have the advantage of  
 41 being environmentally friendly. A number of researchers investigated the absorption cooling  
 42 technology experimentally [12] and numerically [13], while many researchers investigated means of  
 43 improving the adsorption cooling technology including different adsorption system configurations  
 44 [14][15][16], various working pairs [17][18] through modelling[19][20] and experimental work [21].  
 45 However, ORC systems are capable to utilize a range of low grade heat sources and generate  
 46 electricity, it shows relatively low efficiency compared to similar low grade heat utilization  
 47 technologies like adsorption. In addition, air conditioning usually consumes a large amount of

48 electricity especially in hot countries, so it would be more practical to convert the low grade heat into  
 49 cooling and electricity directly and simultaneously to enhance the overall system efficiency and  
 50 reduce the energy conversion losses. Table (2) demonstrate a number of literature that use a range of  
 51 technologies to generate cooling and power at the same time.

**Table 2: Technologies used for cooling and power generation.**

<b>Absorption technology</b>			
<b>Author</b>	<b>Working pair/fluid</b>	<b>Source temp. °C</b>	<b>System performance</b>
Vijayaraghavan, and Goswami [22]	Ammonia/water	87-207	Cycle efficiency increased by 25%.
Hasan et al [23]	Ammonia/water	57-197	Maximum second law efficiency of 65.8%
Liu and Zhang [24]	Ammonia/water	450	18.2% reduction in energy consumption.
Zheng et al [25]	Ammonia/water	350	Thermal and exergy efficiency of 24.2% and 37.3%.
Zhang and Lior [26]	Ammonia/water	450	Thermal and exergy efficiencies of 27.7%, and 55.7%.
<b>Adsorption technology</b>			
<b>Author</b>	<b>Working pair/fluid</b>	<b>Source temp. °C</b>	<b>System performance</b>
Lu et al [27]	12 different salts /ammonia	100-200	40%-60% increase in exergy efficiency compared with Goswami cycle.
Jiang et al [28]	5 different salts/ammonia	100-400	Thermal efficiency of 15.8%, COP of 0.691 and exergy efficiency of 82%.
Wang et al [29]	PbCl <sub>2</sub> / ammonia BaCl <sub>2</sub> / ammonia CaCl <sub>2</sub> / ammonia	100-400	Exergy efficiency improved by 40-60%
Bao et al [30]	MnCl <sub>2</sub> /ammonia	150-210	0.57 COP and 62% exergy efficiency
Bao et al [31]	CaCl <sub>2</sub> /ammonia	120-130	490 W of power and 5.4 °C of chilled water
Jiang et al [32]	MnCl <sub>2</sub> -CaCl <sub>2</sub> -NH <sub>3</sub>	130	300 W of power and 2 kW of cooling and efficiency increases from 31.6% to 37.6%.
Lu et al [33]	12 different salts/ammonia	100-300	COP increased by 38%, electricity efficiency improved from 8% to 12% and second law efficiency reached 41%.
AL-Mousawi et al [34]	MIL101Cr/water	70-90	Cycle efficiency increased from 47% to 50%
AL-Mousawi et al [35]	AQSOA-Z02/water MIL101Cr/water Aluminium-Fumarate/water silica-gel/water	80-160	Small-scale radial inflow turbine of 82% efficiency was designed and modelled using SAPO-34 and total system efficiency of 69% can be achieved.
AL-Mousawi et al [36]	AQSOA-Z02/water MIL101Cr/water silica-gel/water	80-160	SP of 73 W/kg <sub>ads</sub> , and SCP of 681 W/kg <sub>ads</sub> using AQSOA-Z02 and maximum system efficiency of 67% can be achieved.
<b>Adsorption technology and ORC</b>			
<b>Author</b>	<b>Working pair/fluid</b>	<b>Source temp. °C</b>	<b>System performance</b>
Jiang et al [37]	CaCl <sub>2</sub> /BaCl <sub>2</sub> and R245fa	< 100	Energy and exergy efficiencies were 10.1%-13.1% and 18.5%-20.3
Wang et al [38]	silica-gel/water and R600	78 -98	1 kW of electricity and 6.3 kW of refrigeration from 15 kW of heat

52 A number of researchers [22-26] have investigated the production of cooling and power using  
 53 absorption technology, however this technology has a number of negatives like large size, and toxicity

54 of ammonia. Production of cooling and power using adsorption technology was investigated by a  
55 number of researchers [27-36], via incorporating an expander in such system, however, this  
56 configuration may have a limited amount of power generation due to the relatively low refrigerant  
57 mass flow rate passing through the expander (coming from the desorber) especially when small  
58 amount of adsorbent is used.


59 Adsorption is an exothermic process and cooling source is needed during this process to  
60 sustain the cooling in the evaporator and during this process heat is rejected in the bed that  
61 undertaking the adsorption process. Heat recovery is one of the best proposed ways to benefit  
62 from the internal thermal energy of the adsorption cooling system itself, and improving the  
63 overall system's performance. In this point, researchers have put forward some effective  
64 means that promotes a useful use of the internal heat of the system. Wang et al. [39]  
65 experimentally studied the effect of passive heat recovery on the coefficient of performance  
66 and results show that the COPs of a two-bed chiller and a four-bed chiller have improved by  
67 as much as 38% and 25%, respectively, without any effect on their cooling capacities. Pan et  
68 al. [40] studied and compared the theoretical analysis of three heat recovery methods used in  
69 adsorption refrigeration system and results show that serial and passive heat recoveries (part  
70 type) are more optimal than circular heat recovery (complete type) when manufacture and  
71 cost are considered. Leong et al. [41] studied numerically the effect of using combined heat  
72 and mass recovery in adsorption cooling cycle and results show that the proposed cycle can  
73 increase the coefficient of performance (COP) of an adsorption cooling system by more than  
74 47% compared to the single bed system. However, all the previous work does not cover the  
75 use of rejected heat from adsorption process to power another cycle like Organic Rankine  
76 cycle, while, some researchers [37][38] used the heat source leaving the ORC system to  
77 power the adsorption system, but again nobody used the cooling source (with heat recovery)  
78 that leaving the adsorption as a heat source for an ORC system and not all the possible

79 scenarios of integrating the adsorption system with ORC to generate cooling and power  
80 simultaneously were investigated, so there is still a clear gap of using adsorption cycle as a  
81 topping system, while ORC as a bottoming system, where ORC can be totally or partially  
82 powered using the heat recovered from the adsorption system which helps to enhance the  
83 overall system efficiency.

84 In this paper a two bed cooling adsorption system has been integrated with an ORC using four  
85 different scenarios to investigate the feasibility of generating cooling and power simultaneously  
86 utilising low grade heat sources. The system comprises of two adsorption beds, two condensers and  
87 two evaporators and an expander (turbine) using AQSOA-Z02 (SAPO-34)/water and silica-gel/water  
88 as adsorption pairs and R245fa, R365mfc and R141b as ORC working fluids.

### 89 **1. Integrated ORC-adsorption system**


90 Figure (1a) shows a schematic diagram of a basic two-bed adsorption cooling system which consists  
91 of desorber, adsorber, condenser and evaporator. As the adsorption is an exothermic process a cooling  
92 source is used to extract heat from the adsorber and sustain cooling through adsorption process which  
93 helps to desorb the refrigerant from the evaporator and generate the cooling effect. Desorption is an  
94 endothermic process, and a heat source (low grade heat source) is used to sustain heating during this  
95 process which helps to discharge the refrigerant (water vapour) from the hot bed. Then, the hot  
96 refrigerant will be cooled in the condenser to feed the evaporator with the refrigerant liquid and keep  
97 continuous cooling through the system. Figure (1b) shows the adsorption basic cycle on a P-T  
98 diagram; process 1-2 is an adsorbent isosteric heating where a low grade heat source is used and this  
99 heating is still continuous during the process 2-3' while the valve 4 is opened, meanwhile a cold  
100 source is used during the process 3'-4' and this cooling is still continuous during the process 4'-1  
101 while the valve 2 is opened.



103  
104  
105

**Figure 1: shows a basic two-bed adsorption cooling (a) schematic diagram (b) P-T diagram.**

106 The basic Organic Rankine cycle (ORC) as shown in Figure (2) can be powered by a low grade heat  
 107 sources such as solar energy or waste heat and it has four main processes. During process 1-2 the  
 108 refrigerant liquid will be pumped to the evaporator pressure, while through process 2-3 heat is added  
 109 to the evaporator from an external source (low grade heat source). During, 3-4 the refrigerant expands  
 110 through an expander (turbine) where the mechanical power can be produced and finally, through 4-1  
 111 the refrigerant is cooled in the condenser.



112  
113  
114

**Figure 2: Basic ORC cycle (a) schematic diagram (b) P-h diagram.**

115 The main purpose of this study is to investigate the feasibility of producing cooling and power  
116 simultaneously by modifying the two-bed adsorption system to be integrated with an ORC system and  
117 improve the heat utilization efficiency. This study can be carried out using four proposal scenarios as  
118 listed below.

119 a) Adsorption Heat Recovery Scenario (AHRs): in this scenario, the two bed adsorption  
120 cooling system is powered using an external low grade heat source such as solar energy or  
121 geothermal energy to sustain the desorption process in the hot bed. While, during the  
122 adsorption process (in the cold bed) adsorption material needs to be cooled using an  
123 external cooling source to release the heat of adsorption and sustain the adsorption  
124 process and as a result it sustains the cooling effect in the evaporator which is one of the  
125 main outputs of the integrated system. In this scenario, the heat of adsorption can be  
126 recovered by the cooling source fluid and as the cooling source inlet temperature is  
127 relatively high (but still enough to cool the bed under adsorption process), the cooling  
128 source leaving the bed can be used to power an Organic Rankine cycle and generate  
129 electricity without using additional heat. Figure (3) shows the two bed adsorption system  
130 integrated with an ORC system to generate cooling and power simultaneously, where the  
131 adsorption cooling system is used as topping system and the ORC is used as bottoming  
132 system and during this scenario all valves are closed except V6 and V7 as listed in table  
133 (3).

134 b) Return Adsorption Heating Fluid Scenario (RAHFS): in this scenario, the cooling system  
135 is powered using an external low grade heat source such as solar energy or geothermal  
136 energy to sustain desorption process in the hot bed, while a cooling source is used to  
137 sustain the adsorption process. The adsorption cooling system is used as topping system  
138 and ORC is used as bottoming system and in this case ORC system is powered using the  
139 same low grade heat source line leaving the hot bed in the adsorption cooling system  
140 (topping system), so additional heat can be consumed by the ORC system and more  
141 electricity is expected to be generated using this scenario and this is due to using



142 relatively high driving temperature to power the ORC system. Figure (3) shows the two  
143 bed adsorption system integrated with an ORC system to generate cooling and power  
144 simultaneously, where the ORC (bottoming system) is powered using the hot line (water  
145 or pressurized water depends on the heat source temperature) leaving the adsorption  
146 system (topping system) and during this scenario all valves are closed except V5 and V8  
147 as shown in table (3).

148 c) Heat Exchanger Scenario (HES): in this scenario, the adsorption cooling system is  
149 powered by an external low grade heat source to drive the hot bed during desorption  
150 process, while a cooling source is used in the cold bed. This scenario is similar to AHRS,  
151 where again the cooling source line recovers the heat of adsorption from the cold bed  
152 during adsorption process. This recovered heat can be partially used to power an Organic  
153 Rankine cycle and generate electricity, where additional heat from the external heat  
154 source is added in this scenario (by using additional heat exchanger) to enhance the  
155 efficiency of the ORC system. Figure (3) shows that the hot line (water or pressurized  
156 water) and the cold line leaving the adsorption system enter a heat exchanger to add  
157 additional amount of heat from the hot line to the leaving cold line, so this heat (the  
158 recovered heat and the additional heat) is used to power the ORC system and in this  
159 scenario, all valves are open except V8 as shown in table (3).

160 d) Return ORC Heating Fluid Scenario (RORCHFS): in this scenario, the ORC system is  
161 used as the topping system while the adsorption cooling system is used as the bottoming  
162 system and an external low grade heat source is used to power the ORC system. The  
163 heating fluid leaving the ORC system is used directly to power the two bed adsorption  
164 system and as results, the integrated system (of adsorption system and ORC system) can  
165 generate cooling and power at the same time. Figure (4) shows the integration of ORC  
166 and adsorption cooling system using this scenario.


167

168

**Table 3: Scenarios AHRS, RAHFS and HES valves situation.**

Scenario	V5	V6	V7	V8	V9
AHRS	C	O	O	C	C
RAHFS	O	C	C	O	C
HES	O	O	O	C	O


169



170

171

**Figure 3: Schematic diagram of an adsorption –ORC integrated system scenarios 1, 2 and 3.**



172

173


**Figure 4: Schematic diagram of an adsorption –ORC integrated system scenarios 4.**

174

175

## 176 2. Adsorbent materials properties

177 In this study AQSOA-Z02 (SAPO-34) is used and compared to silica-gel and this material is  
178 considered to be an advanced (synthetic zeolite) with a unique adsorbent performance that has been  
179 developed by MITSUBISHI PLASTIC Company using inorganic material design technology. Figure  
180 (5a) shows scanning electron microscope SEM image of AQSOA-Z02 which has solid regular cubic  
181 or brick shape with a uniform particle and it has smaller particle size compared to silica-gel. Figure  
182 (5b) shows the AQSOA-Z02 structure where, it has pore size of 0.38 nm compared to the water  
183 molecule size of 0.3 nm.



184

185 **Figure 5: (a) SEM image for AQSOA Z02, and (b)CHA structure for AQSOA Z02 [42].**

186 Figure (6) shows the measured isotherms of AQSOA-Z02 (SAPO-34)/water (experimental data from  
187 a DVS analyser) at three temperatures (25 °C, 35 °C and 45 °C) and the corresponding curve fitting  
188 lines [36]. In this figure, the experimental data is fitted to the equation that developed by Sun and  
189 Chakraborty [43] (equation 1) and a good agreement is obtained between the experimental data  
190 (dotted lines) and the predicted data (continuous lines) at all temperatures (25 °C, 35 °C and 45 °C)  
191 with maximum deviation of about ±12%. The constants obtained from this fitting are listed in table  
192 (4), while the equation is given by:


$$193 \quad x_{eq} = x_o \left[ \frac{k \left(\frac{p}{p_s}\right)^n}{1 + (K-1) \left(\frac{p}{p_s}\right)^n} \right] \quad (1)$$

$$194 \quad k = \alpha \exp \left[ n(Q_{st} - h_{fg}) / RT \right] \quad (2)$$

195 **Table 4: Constants used in Equations (1) and (2) [36].**

Property	Value	Unit
$x_o$	0.285	kg/kg <sub>ads</sub>
$\alpha$	1032	-
$n$	3.18	-
$Q_{st}$	3420	kJ/kg

196



197

198 **Figure 6: Isotherms fitting of experimental and predicted uptake of AQSOA Z02 (SPO-34)/water[36].**

199 The modified Freundlich equation is used to present the adsorption isotherms of silica-gel/water  
 200 [44][45][46] as:

$$201 \quad x_{eq} = A(T_s) \left[ \frac{p}{p_s} \right]^{B(T_s)} \quad (3)$$

202 Where

$$203 \quad A(T_s) = A_o + A_1 T_s + A_2 T_s^2 + A_3 T_s^3 \quad (4)$$

$$204 \quad B(T_s) = B_o + B_1 T_s + B_2 T_s^2 + B_3 T_s^3 \quad (5)$$

205 The constants of equations (4) and (5) are obtained from [46][47]. Adsorption and desorption is a time  
 206 dependant process and are assumed to be controlled by macroscopic diffusion and the linear driving  
 207 force (LDF) equation is used to define the adsorption/desorption rate as [44][45][48]

$$208 \quad \frac{dx}{dt} = k_o \exp(-E_a/RT)(x_{eq} - x) \quad (6)$$

209 For AQSOA-Z02 (SAPO-34)/water, the kinetics constants of equation (6) are obtained from [49],  
 210 while for silica-gel/water the values of kinetics constants used in equation (6) are :  $k_o= 1.3183 \text{ E}+05$   
 211  $1/s$  and  $E_a= 42000 \text{ J/mole}$  [44][45].

### 212 3. Integrated system energy balance

213 The lumped model technique is used to describe the energy balance equations in the two adsorbent  
 214 beds used in this study, where the adsorbent, the refrigerant and the bed materials are assumed to be at  
 215 the same temperature at all time of the cycle[48][50][51].

$$216 \left( M C_{p_{\text{eff}}}^{\text{bed}} \right) \frac{dT^{\text{bed}}}{dt} + \left( M_a x_i^{\text{bed}} c_p \right) \frac{dx_i^{\text{bed}}}{dt} = \varphi M_a \left( \frac{dx_i^{\text{bed}}}{dt} \right) (Q_{st}) - (\dot{m} c_p)_j (T_{j,o} - T_{j,in}) \quad (7)$$

217 Flag  $\varphi$  equals to 0 at switching time and equals to 1 at adsorption/desorption process. The first term  
 218 on the left side of the equation (7) shows the internal energy change in heat exchanger material,  
 219 including the fins and the tubes, while the second term represents the change in internal energy of the  
 220 refrigerant (water). The first term on the right side of equation (7) represents the heat  
 221 generated/rejected during the adsorption/desorption process respectively. The last term describes heat  
 222 added/rejected to the coolant during the adsorption/desorption process and the bed outlet temperature  
 223 is given by: [48][50]

$$224 T_{j,o} = T_i^{\text{bed}} + (T_{j,in} - T_i^{\text{bed}}) \exp \left[ \frac{-(U A_r)_i^{\text{bed}}}{(\dot{m} c_p)_j} \right] \quad (8)$$

225 The energy balance equations for the condenser can be expressed by [51][52]

$$226 \left( M C_{p_{\text{eff}}}^{\text{cond}} \right) \frac{dT^{\text{cond}}}{dt} = \varphi H_{fg} M_a \frac{dx_{\text{des}}^{\text{bed}}}{dt} - (\dot{m} c_p)_{\text{cond}} (T_{w,o} - T_{w,i}) - (c_p)_w (T^{\text{bed}} - T^{\text{cond}}) M_a \frac{dx_{\text{des}}^{\text{bed}}}{dt} \quad (9)$$

227 The condenser outlet temperature is given by [51][52]

$$228 T_{w,o} = T^{\text{cond}} + (T_{w,in} - T^{\text{cond}}) \exp \left[ \frac{-(U A_r)^{\text{cond}}}{(\dot{m} c_p)_{\text{cond}}} \right] \quad (10)$$

229 The energy balance in the evaporator is expressed as [51][52]

$$230 \quad \left( M c_{p, \text{eff}}^{\text{evap}} \right) \frac{dT^{\text{evap}}}{dt} = \phi H_{fg} M_a \frac{dx_{\text{ads}}^{\text{bed}}}{dt} - (\dot{m} c_p)_{\text{evap}} (T_{\text{chill},o} - T_{\text{chill},i}) - (c_p)_w (T^{\text{cond}} - T^{\text{evap}}) M_a \frac{dx_{\text{des}}^{\text{bed}}}{dt} \quad (11)$$

231 The outlet temperature of the chilled water can be written as [45][52][51]

$$232 \quad T_{\text{chill},o} = T^{\text{evap}} + (T_{\text{chill},in} - T^{\text{evap}}) \exp \left[ \frac{-(U A_r)^{\text{evap}}}{(\dot{m} c_p)_{\text{evap}}} \right] \quad (12)$$

233 The mass balance of liquid refrigerant in the adsorption evaporator is given as [45][48][50][51]

$$234 \quad \frac{dM_{\text{ref}}}{dt} = -M_a \left[ \frac{dx_{\text{des}}^{\text{bed}}}{dt} + \frac{dx_{\text{ads}}^{\text{bed}}}{dt} \right] \quad (13)$$

235 Heat added to the ORC evaporator ( $Q_{in}$ ) and heat rejected in the ORC condenser ( $Q_{out}$ ) can be  
236 written as [53][54][55] :

$$237 \quad Q_{in} = \dot{m}_{e,orc} c_p (T_{e,i} - T_{e,o}) \quad (14)$$

$$238 \quad Q_{out} = \dot{m}_{c,orc} c_p (T_{c,i} - T_{c,o}) \quad (15)$$

239 In equation (14),  $\dot{m}_{e,orc}$  is the mass flow rate of heating fluid (water or pressurized water) passing  
240 through the ORC evaporator which equals to the bed cooling fluid (water) mass flow in AHRS and  
241 HES, the bed heating fluid mass flow in RAHFS and to the main heat source mass flow in  
242 RORCHFS.  $T_{e,i}$  is the inlet temperature of ORC evaporator which equals to cooling fluid leaving the  
243 hot bed in AHRS, the heating fluid leaving the hot bed in RAHFS, the cooling fluid leaving the cold  
244 bed and the heat exchanger in HES and the main heat source temperature in RORCHFS, while  $T_{e,o}$  is  
245 temperature of the fluid leaving the ORC evaporator. In equation (15),  $\dot{m}_{c,orc}$  is the mass flow rate of  
246 the cooling fluid (water) using to cool the ORC condenser which is constant during this study as  
247 shown in table (5), while  $T_{c,i}$  and  $T_{c,o}$  are the inlet and the outlet cooling fluid temperatures of the ORC  
248 condenser and as shown in figures (2-4) the isentropic efficiency of the ORC turbine can be given by:

$$249 \quad \eta_T = \frac{h_3 - h_4}{h_3 - h_{4s}} \quad (16)$$

250 The power generated by the ORC turbine can be calculated as:

$$251 \quad W_{\text{turbine}} = \eta_{\text{turbine}} \dot{m}_{\text{ORC}} (h_3 - h_4) \quad (17)$$

252 The ORC cycle thermal efficiency can be calculated as:

253  $\eta_{ORC} = \frac{W_{turbine} - W_{pump}}{Q_{in}}$  (18)

254 The power consumed in pump can be calculated as:

255  $W_{pump} = \frac{\dot{m}_{ORC}(P2-P1)}{\rho_1 \eta_{pump}}$  (19)

256 The overall performance of the integrated system is evaluated using the specific cooling power (SCP),  
 257 specific generated power (SP), the cooling coefficient of performance (COP) and overall system  
 258 efficiency as expressed in equations (20-23).

259  $SCP = \frac{(\dot{m}_{cp})_{evap} \int_0^{t_{cycle}} (T_{chill,o} - T_{chill,i}) dt}{M_a t_{cycle}}$  (20)


260  $SP = \frac{\int_0^{t_{cycle}} \dot{m}_{ORC} (h_3 - h_4) dt}{M_a t_{cycle}}$  (21)

261  $COP = \frac{(\dot{m}_{cp})_{evap} \int_0^{t_{cycle}} (T_{chill,o} - T_{chill,i}) dt}{(\dot{m}_{cp})_h \int_0^{t_{cycle}} (T_{h,o} - T_{h,i}) dt}$  (22)

262  $system\ efficiency = \frac{(\dot{m}_{cp})_{evap} \int_0^{t_{cycle}} (T_{chill,o} - T_{chill,i}) dt + \int_0^{t_{cycle}} \dot{m}_{ORC} (h_3 - h_4) dt}{(\dot{m}_{cp})_h \int_0^{t_{cycle}} (T_{h,o} - T_{h,i}) dt}$  (23)

263 **4. System modelling**

264 MATLAB Simulink software is used to simulate the integration a two bed adsorption system  
 265 with an ORC system to study the feasibility of generating cooling and electricity  
 266 simultaneously. The main components of the adsorption system such as beds, condenser and  
 267 evaporator in addition to the ORC system are presented in a flow chart as shown in figure (7)  
 268 to highlight the main steps used to solve the system equations (1-23).



269

270

271

272

## 5. Results and discussion

273

274

275

276

277

278

279

280

281

282

283

284

Figure 7: System modelling flow chart.

Table (5) shows the main operating conditions where the same conditions were applied for all scenarios except the cold bed temperature (48 °C for AHRS and HES) and the ORC condenser temperature (25 °C for AHRS and HES), while table (6) shows the characteristics of main components used in this study. Figure (8) shows the output of the adsorption-ORC integration system for cooling and power using AQSOA-Z02 (SAPO-34)/water as a working fluid and utilising heat source temperatures of 95 °C. The cycle can produce average cooling and power of up to 2.73 kW (using RAHFS) and 1.17 kW (using RORCHFS and R141b) respectively. Figure (9) compares the COP of adsorption cooling system and the efficiencies of ORC system and integrated adsorption-ORC system for the four proposed scenarios using a range of heat source temperatures utilising silica-gel/water as adsorption pair and R245fa, R365mfc and R141b as ORC fluids. Results show that, AHRS has the maximum integrated system efficiency of about 70% and this is because no additional heat is used in this scenario and ORC is powered only by the heat recovered from



285 adsorption cycle. Also HES has relatively high overall efficiencies compared to RAHFS and  
286 RORCHFS because HES is similar to AHRS, with a limited amount of additional heat that  
287 used through the heat exchanger. Figure (10) presents similar data but, using AQSOA Z02  
288 (SAPO-34)/water as adsorption pair and again AHRS shows the highest integrated system  
289 efficiency of 60%, while HES has relatively high overall efficiencies compared to RAHFS  
290 and RORCHFS and this is for the same reason as for silica-gel/water. Figure (11) shows the  
291 SCP and SP of the integrated adsorption-ORC system for the four proposed scenarios  
292 utilising silica-gel/water and R245fa, R365mfc and R141b. Results show that, AHRS and  
293 HES show the lowest value of SCP due to using relatively high cooling source temperature  
294 and the lowest value of SP due to the relatively low pressure ratio through the ORC turbine  
295 caused by low temperature in the ORC evaporator. RAHFS shows the highest SCP of almost  
296 432 W/kg<sub>ads</sub> using silica-gel because adsorption system is the topping system where more  
297 heat is applied to the adsorption beds. RORCHFS shows the highest SP of almost 169  
298 W/kg<sub>ads</sub> using silica-gel and R141b with heat source temperature of 115 °C and this is due to  
299 ORC is topping system and more heat is added to the ORC evaporator in this scenario. Figure  
300 (12) presents similar data but, for AQSOA Z02(SAPO-34)/water and results show that  
301 RAHFS shows the highest SCP of almost 616 W/kg<sub>ads</sub> and RORCHFS shows the maximum  
302 SP of 208 W/kg<sub>ads</sub> using R141b and heat source temperature of 115 °C.

303 The four different scenarios used in this investigation can offer a range of options not only to  
304 the designers of energy systems, but also to the energy consumers. For example, in hot  
305 countries, air conditioning and refrigeration are considered to be the largest portion of the  
306 total residential energy consumption, and the proposed integrated system can be used as  
307 localized units to generate cooling and electricity simultaneously especially in the remote or  
308 off-grid areas (areas which are not connected to the national or main electricity grid), also this  
309 helps to increase the overall utilization efficiency of the low grade heat sources. AHRS is

310 preferable when limited amount of low grade heat source is available because this scenario  
 311 can generate cooling and electricity simultaneously with high efficiency. Even though,  
 312 RAHFS and RORCHFS can generate cooling and power at the same time with relatively high  
 313 SP and SCP, the efficiencies of those scenarios are low compared to the efficiencies of AHRS  
 314 and HES. However, if the used low grade heat source is infinite or semi-infinite like solar  
 315 energy (as in many hot countries around the world) those scenarios can be more preferable. In  
 316 addition, in this study energy losses through turbine and pump are considered where the  
 317 efficiencies of the turbine and the pump are assumed to be 85% and 65% respectively as  
 318 listed in table (5), while the energy losses through heat exchangers, pipes, and valves are  
 319 neglected, because they are expected to be thermally insulated.

320 **Table 5: Parameters used in the simulation.**

<b>Parameter</b>	<b>Value</b>
Bed heating fluid temperature °C	95-115
Bed cooling fluid temperature °C	48 <sup>a</sup> /30
Condenser cooling temperature °C	30
Chilled water temperature °C	14
Bed hot fluid mass flow rate kg/s	1.7
Bed cold fluid mass flow rate kg/s	1.6
Condenser mass flow rate kg/s	0.75
Evaporator mass flow rate kg/s	0.75
Half cycle time s	320
Switching time s	20
ORC condenser temperature °C	25 <sup>a</sup> /30
ORC condenser mass flow kg/s	0.8
ORC refrigerant mass flow kg/s	0.04
Expander (turbine) efficiency %	85
Pump efficiency %	65

321  
 322 a: conditions used only in AHRS and HES

323 **Table 6: System characteristics [36][56].**

324 **(a) Bed heat exchanger characteristics**

Parameter	Value
Fin length m	172E-3
Fin width m	30E-3
Fin pitch m	1.2E-3
Module length m	450E-3
No. of module	4
No. tubes/module	6
Tube OD m	15.875E-3
Tube thickness m	0.8E-3


325 **(b) Adsorption condenser/evaporator characteristics**

Parameter	Value
Pipe length m	5.5
No. tubes	4
Tube OD m	15.875E-3
Tube thickness m	0.8E-3

326 **(c) ORC condenser/evaporator characteristics**


Parameter	Value
Pipe length m	5.5
No. tubes	8
Tube OD m	15.875E-3
Tube thickness m	0.8E-3

327




328


329



330



331




332


Figure 8: Cooling and power generating using SAPO-34/water with heat source temperature of 95 °C .

333


334



335



336




337


Figure 9: Effect of using the four scenarios on COP and system efficiencies utilising silica-gel/water.

338


339



340




341




342

Figure 10: Effect of using the four scenarios on COP and system efficiencies utilising SAPO-34/water.


343



344




345




346

Figure 11: Effect of using the four scenarios on the SCP and SP utilising silica-gel/water.


347



348



349



350

Figure 12: Effect of using the four scenarios on the SCP and SP utilising SAPO-34/water.

351

352



353 **6. Conclusion**

354 A two-bed adsorption cooling system has been integrated with an Organic Rankine cycle (ORC) to  
355 generate cooling and electricity simultaneously using four different scenarios. In the first three  
356 scenarios, adsorption system is set up as a topping system, while ORC is set up as a bottoming  
357 system. The first scenario AHRS, the adsorption heat is recovered from the adsorption bed and used  
358 to power the ORC system, and in this case, no additional heat is applied. The second scenario  
359 RAHFS, the heating fluid leaving the adsorption system is used to power the ORC system. In the third  
360 scenario HES, a heat exchanger is used to add more heat from the heating source to the cooling line  
361 leaving the adsorption system to enhance the performance of the ORC. In the fourth scenario  
362 RORCHFS, the ORC system is set as a topping system, while the adsorption system is set as a  
363 bottoming system and the adsorption system is powered using the heating fluid leaving the ORC  
364 system.. AQSOA-ZO2 (SAPO-34)/water and silica-gel/water have been used as adsorption working  
365 pairs, while R245fa, R365mfc and R141b have been used as an ORC working fluids. The main results  
366 of this investigation can be summarised as:

- 367 1. Integrating adsorption cooling system with ORC offers the advantage of generating cooling  
368 and power simultaneously and it can improve the overall system efficiency.
- 369 2. The four proposed scenarios offer wide-range options for energy designers and customers to  
370 use localised cooling and power generation units that utilize low grade heat sources.
- 371 3. AHRS achieved the maximum integrated system efficiency of 60% utilizing SAPO-34/water  
372 and R141b and 70% utilizing silica-gel/water and R141b.
- 373 4. RAHFS and RORCHFS achieved the maximum COP of about 0.63 and 0.53 using silica gel  
374 and SAPO-34 respectively.
- 375 5. Utilizing SAPO-34 and R141b in RORCHFS achieved the maximum specific power of 208  
376 W/kg<sub>ads</sub>, while in RAHFS they achieved the maximum specific cooling power of 616 W/kg<sub>ads</sub>.
- 377 6. Using heat exchanger in HES can slightly increase the ORC efficiency and SP, but decrease  
378 the integrated system efficiency compared to AHRS because of using additional heat.

379 **Acknowledgement**

380 The authors would like to acknowledge the Iraqi Government and The Iraqi Ministry of Higher  
381 Education and Scientific Research for sponsoring this work.

382 **References**

- 383 [1] S. M. Moosavian, N. A. Rahim, J. Selvaraj, and K. H. Solangi, “Energy policy to  
384 promote photovoltaic generation,” *Renew. Sustain. Energy Rev.*, vol. 25, pp. 44–58,  
385 2013.
- 386 [2] T. C. Hung, T. Y. Shai, and S. K. Wang, “A review of organic rankine cycles (ORCs)  
387 for the recovery of low-grade waste heat,” *Energy*, vol. 22, no. 7, pp. 661–667, 1997.
- 388 [3] R. Rayegan and Y. X. Tao, “A procedure to select working fluids for Solar Organic  
389 Rankine Cycles (ORCs),” *Renew. Energy*, vol. 36, no. 2, pp. 659–670, 2011.
- 390 [4] F. A. Al-Sulaiman, F. Hamdullahpur, and I. Dincer, “Greenhouse gas emission and  
391 exergy assessments of an integrated organic Rankine cycle with a biomass combustor  
392 for combined cooling, heating and power production,” *Appl. Therm. Eng.*, vol. 31, no.  
393 4, pp. 439–446, 2011.
- 394 [5] T. Guo, H. X. Wang, and S. J. Zhang, “Fluids and parameters optimization for a novel  
395 cogeneration system driven by low-temperature geothermal sources,” *Energy*, vol. 36,  
396 no. 5, pp. 2639–2649, 2011.
- 397 [6] V. L. Le, M. Feidt, A. Kheiri, and S. Pelloux-Prayer, “Performance optimization of  
398 low-temperature power generation by supercritical ORCs (organic Rankine cycles)  
399 using low GWP (global warming potential) working fluids,” *Energy*, vol. 67, pp. 513–  
400 526, 2014.
- 401 [7] G. Pei, J. Li, and J. Ji, “Analysis of low temperature solar thermal electric generation  
402 using regenerative Organic Rankine Cycle,” *Appl. Therm. Eng.*, vol. 30, no. 8–9, pp.  
403 998–1004, 2010.
- 404 [8] P. J. Mago, L. M. Chamra, K. Srinivasan, and C. Somayaji, “An examination of  
405 regenerative organic Rankine cycles using dry fluids,” *Appl. Therm. Eng.*, vol. 28, no.  
406 8–9, pp. 998–1007, 2008.
- 407 [9] I. H. Aljundi, “Effect of dry hydrocarbons and critical point temperature on the  
408 efficiencies of organic Rankine cycle,” *Renew. Energy*, vol. 36, no. 4, pp. 1196–1202,  
409 2011.
- 410 [10] B. F. Tchanche, G. Papadakis, G. Lambrinos, and A. Frangoudakis, “Fluid selection  
411 for a low-temperature solar organic Rankine cycle,” *Appl. Therm. Eng.*, vol. 29, no.  
412 11–12, pp. 2468–2476, 2009.
- 413 [11] J. P. Roy, M. K. Mishra, and A. Misra, “Performance analysis of an Organic Rankine  
414 Cycle with superheating under different heat source temperature conditions,” *Appl.  
415 Energy*, vol. 88, no. 9, pp. 2995–3004, 2011.
- 416 [12] F. Asdrubali and S. Grignaffini, “Experimental evaluation of the performances of a  
417 H<sub>2</sub>O-LiBr absorption refrigerator under different service conditions,” *Int. J. Refrig.*,  
418 vol. 28, no. 4, pp. 489–497, 2005.
- 419 [13] G. A. Florides, S. A. Kalogirou, S. A. Tassou, and L. C. Wrobel, “Design and  
420 construction of a LiBr-water absorption machine,” *Energy Convers. Manag.*, vol. 44,  
421 no. 15, pp. 2483–2508, 2003.
- 422 [14] N. D. Banker, M. Prasad, P. Dutta, and K. Srinivasan, “Activated carbon + HFC 134a  
423 based two stage thermal compression adsorption refrigeration using low grade thermal  
424 energy sources,” *Appl. Therm. Eng.*, vol. 29, no. 11–12, pp. 2257–2264, 2009.
- 425 [15] M. Z. I. Khan, K. C. A. Alam, B. B. Saha, A. Akisawa, and T. Kashiwagi, “Study on a

- 426 re-heat two-stage adsorption chiller - The influence of thermal capacitance ratio,  
 427 overall thermal conductance ratio and adsorbent mass on system performance,” *Appl.*  
 428 *Therm. Eng.*, vol. 27, no. 10, pp. 1677–1685, 2007.
- 429 [16] A. S. Uyun, A. Akisawa, T. Miyazaki, Y. Ueda, and T. Kashiwagi, “Numerical  
 430 analysis of an advanced three-bed mass recovery adsorption refrigeration cycle,” *Appl.*  
 431 *Therm. Eng.*, vol. 29, no. 14–15, pp. 2876–2884, Oct. 2009.
- 432 [17] W. S. Loh, I. I. El-Sharkawy, K. C. Ng, and B. B. Saha, “Adsorption cooling cycles for  
 433 alternative adsorbent/adsorbate pairs working at partial vacuum and pressurized  
 434 conditions,” *Appl. Therm. Eng.*, vol. 29, no. 4, pp. 793–798, 2009.
- 435 [18] L. W. Wang, R. Z. Wang, and R. G. Oliveira, “A review on adsorption working pairs  
 436 for refrigeration,” *Renew. Sustain. Energy Rev.*, vol. 13, no. 3, pp. 518–534, 2009.
- 437 [19] X. Wang and H. T. Chua, “Two bed silica gel–water adsorption chillers: An effectual  
 438 lumped parameter model,” *Int. J. Refrig.*, vol. 30, no. 8, pp. 1417–1426, Dec. 2007.
- 439 [20] H. T. Chua, K. C. Ng, W. Wang, C. Yap, and X. L. Wang, “Transient modeling of a  
 440 two-bed silica gel–water adsorption chiller,” *Int. J. Heat Mass Transf.*, vol. 47, no. 4,  
 441 pp. 659–669, Feb. 2004.
- 442 [21] W. Chang, C. Wang, and C. Shieh, “Experimental study of a solid adsorption cooling  
 443 system using flat-tube heat exchangers as adsorption bed,” *Appl. Therm. Eng.*, vol. 27,  
 444 pp. 2195–2199, 2007.
- 445 [22] S. Vijayaraghavan and D. Y. Goswami, “A combined power and cooling cycle  
 446 modified to improve resource utilization efficiency using a distillation stage,” *Energy*,  
 447 vol. 31, no. 8–9, pp. 1177–1196, 2006.
- 448 [23] A. A. Hassan, Y. Goswami, and S. Vijayaraghavan, “First and Second Law Analysis  
 449 of a New Power and Refrigeration Thermodynamic Cycle Using a Solar Heat Source,”  
 450 *Sol. Energy*, vol. 73, no. 5, pp. 385–393, 2003.
- 451 [24] M. Liu and N. Zhang, “Proposal and analysis of a novel ammonia-water cycle for  
 452 power and refrigeration cogeneration,” *Energy*, vol. 32, no. 6, pp. 961–970, 2007.
- 453 [25] D. Zheng, B. Chen, Y. Qi, and H. Jin, “Thermodynamic analysis of a novel absorption  
 454 power/cooling combined-cycle,” *Appl. Energy*, vol. 83, no. 4, pp. 311–323, 2006.
- 455 [26] N. Zhang and N. Lior, “Development of a Novel Combined Absorption Cycle for  
 456 Power Generation and Refrigeration,” *J. Energy Resour. Technol.*, vol. 129, no. 3, p.  
 457 254, 2007.
- 458 [27] Y. Lu, H. Bao, Y. Yuan, Y. Wang, L. Wang, and A. P. Roskilly, “Optimisation of a  
 459 novel resorption cogeneration using mass and heat recovery,” *Energy Procedia*, vol.  
 460 61, pp. 1103–1106, 2014.
- 461 [28] L. Jiang, L. W. Wang, A. P. Roskilly, and R. Z. Wang, “Design and performance  
 462 analysis of a resorption cogeneration system,” *Int. J. Low-Carbon Technol.*, vol. 8, no.  
 463 SUPPL1, pp. 85–91, 2013.
- 464 [29] L. Wang, F. Ziegler, A. P. Roskilly, R. Wang, and Y. Wang, “A resorption cycle for  
 465 the cogeneration of electricity and refrigeration,” *Appl. Energy*, vol. 106, pp. 56–64,  
 466 2013.
- 467 [30] H. Bao, Y. Wang, and A. P. Roskilly, “Modelling of a chemisorption refrigeration and  
 468 power cogeneration system,” *Appl. Energy*, vol. 119, pp. 351–362, 2014.
- 469 [31] H. Bao, Y. Wang, C. Charalambous, Z. Lu, L. Wang, R. Wang, and A. P. Roskilly,

- 470 “Chemisorption cooling and electric power cogeneration system driven by low grade  
471 heat,” *Energy*, vol. 72, pp. 590–598, 2014.
- 472 [32] L. Jiang, L. W. Wang, X. F. Zhang, C. Z. Liu, and R. Z. Wang, “Performance  
473 prediction on a resorption cogeneration cycle for power and refrigeration with energy  
474 storage,” *Renew. Energy*, vol. 83, pp. 1250–1259, 2015.
- 475 [33] Y. Lu, Y. Wang, H. Bao, Y. Yuan, L. Wang, and A. P. Roskilly, “Analysis of an  
476 optimal resorption cogeneration using mass and heat recovery processes,” *Appl.  
477 Energy*, vol. 160, pp. 892–901, 2015.
- 478 [34] F. Al-mousawi, R. Al-dadah, and S. Mahmoud, “MIL101Cr MOF – Water Adsorption  
479 System for Cooling and Power Generation Using Waste Heat,” *SusTEM2015  
480 Conference Proceedings*, pp. 291–301, 2015. Avialble online at  
481 <http://research.ncl.ac.uk/sustem/sustem2015conference/proceedings/>
- 482 [35] F. N. Al-Mousawi, R. Al-Dadah, and S. Mahmoud, “Low grade heat driven adsorption  
483 system for cooling and power generation with small-scale radial inflow turbine” *Appl.  
484 Energy*, vol. 183, pp. 1302–1316, 2016.
- 485 [36] F. N. Al-Mousawi, R. Al-Dadah, and S. Mahmoud, “Low grade heat driven adsorption  
486 system for cooling and power generation using advanced adsorbent materials,” *Energy  
487 Convers. Manag.*, vol. 126, pp. 373–384, 2016.
- 488 [37] L. Jiang, L. Wang, R. Wang, P. Gao, and F. Song, “Investigation on cascading  
489 cogeneration system of ORC (Organic Rankine Cycle) and CaCl<sub>2</sub>/BaCl<sub>2</sub> two-stage  
490 adsorption freezer,” *Energy*, vol. 71, pp. 377–387, 2014.
- 491 [38] L. Wang, A. P. Roskilly, R. Wang, P. Taylor, “Solar Powered Cascading Cogeneration  
492 Cycle with ORC and Adsorption Technology for Electricity and Refrigeration,” *Heat  
493 Transf. Eng.*, vol. 35, no. 11–12, pp. 1028–1034, 2014.
- 494 [39] X. Wang, H. T. Chua, and K. C. Ng, “Experimental investigation of silica gel-water  
495 adsorption chillers with and without a passive heat recovery scheme,” *Int. J. Refrig.*,  
496 vol. 28, no. 5, pp. 756–765, 2005.
- 497 [40] Q. W. Pan, R. Z. Wang, and L. W. Wang, “Comparison of different kinds of heat  
498 recoveries applied in adsorption refrigeration system,” *Int. J. Refrig.*, vol. 55, pp. 37–  
499 48, 2015.
- 500 [41] K. C. Leong and Y. Liu, “Numerical study of a combined heat and mass recovery  
501 adsorption cooling cycle,” *Int. J. Heat Mass Transf.*, vol. 47, no. 22, pp. 4761–4770,  
502 2004.
- 503 [42] MITSUBISHI PLASTICS, Zeolite, AQSOA,  
504 [https://www.mpi.co.jp/english/products/industrial\\_materials/im010.html](https://www.mpi.co.jp/english/products/industrial_materials/im010.html)
- 505 [43] B. Sun and A. Chakraborty, “Thermodynamic formalism of water uptakes on solid  
506 porous adsorbents for adsorption cooling applications,” *APPLIED PHYSICS  
507 LETTERS* vol.104, 201901, 2014. vol. 201901, 2014.
- 508 [44] T. Miyazaki, A. Akisawa, B. B. Saha, I. I. El-Sharkawy, and A. Chakraborty, “A new  
509 cycle time allocation for enhancing the performance of two-bed adsorption chillers,”  
510 *Int. J. Refrig.*, vol. 32, no. 5, pp. 846–853, 2009.
- 511 [45] B. B. Saha, S. Koyama, T. Kashiwagi, A. Akisawa, K. C. Ng, and H. T. Chua, “Waste  
512 heat driven dual-mode, multi-stage, multi-bed regenerative adsorption system,” *Int. J.  
513 Refrig.*, vol. 26, no. 7, pp. 749–757, 2003.

- 514 [46] I. I. El-Sharkawy, H. Abdelmeguid, and B. B. Saha, "Towards an optimal performance  
515 of adsorption chillers: Reallocation of adsorption/desorption cycle times," *Int. J. Heat*  
516 *Mass Transf.*, vol. 63, pp. 171–182, 2013.
- 517 [47] H. Z. Hassan, A. A. Mohamad, Y. Alyousef, and H. A. Al-ansary, "A review on the  
518 equations of state for the working pairs used in adsorption cooling systems," *Renew.*  
519 *Sustain. Energy Rev.*, vol. 45, pp. 600–609, 2015.
- 520 [48] A. Sadeghlu, M. Yari, S. M. S. Mahmoudi, and H. B. Dizaji, "Performance evaluation  
521 of Zeolite 13X/CaCl<sub>2</sub> two-bed adsorption refrigeration system," *Int. J. Therm. Sci.*,  
522 vol. 80, no. 1, pp. 76–82, 2014.
- 523 [49] P. G. Youssef, S. M. Mahmoud, and R. K. AL-Dadah, "Performance analysis of four  
524 bed adsorption water desalination/refrigeration system, comparison of AQSOA-Z02 to  
525 silica-gel," *Desalination*, vol. 375, pp. 100–107, 2015.
- 526 [50] B. B. Saha, E. C. Boelman, and T. Kashiwagi, "Computational analysis of an advanced  
527 adsorption-refrigeration cycle," *Energy*, vol. 20, no. 10, pp. 983–994, 1995.
- 528 [51] C. Y. Tso, C. Y. H. Chao, and S. C. Fu, "Performance analysis of a waste heat driven  
529 activated carbon based composite adsorbent - Water adsorption chiller using  
530 simulation model," *Int. J. Heat Mass Transf.*, vol. 55, no. 25–26, pp. 7596–7610, 2012.
- 531 [52] S. K. Farid, M. M. Billah, M. Z. I. Khan, M. M. Rahman, and U. M. Sharif, "A  
532 numerical analysis of cooling water temperature of two-stage adsorption chiller along  
533 with different mass ratios," *Int. Commun. Heat Mass Transf.*, vol. 38, no. 8, pp. 1086–  
534 1092, 2011.
- 535 [53] S. Safarian and F. Aramoun, "Energy and exergy assessments of modified Organic  
536 Rankine Cycles ( ORCs )," *Energy Reports*, vol. 1, pp. 1–7, 2015.
- 537 [54] P. Collings, Z. Yu, and E. Wang, "A dynamic organic Rankine cycle using a zeotropic  
538 mixture as the working fluid with composition tuning to match changing ambient  
539 conditions," *Appl. Energy*, vol. 171, pp. 581–591, 2016.
- 540 [55] K. Rahbar, S. Mahmoud, R. K. Al-dadah, and N. Moazami, "Modelling and  
541 optimization of organic Rankine cycle based on a small-scale radial inflow turbine,"  
542 *Energy Convers. Manag.*, vol. 91, pp. 186–198, 2015.
- 543 [56] B. Shi, R. Al-Dadah, S. Mahmoud, A. Elsayed, and E. Elsayed, "CPO-27(Ni) metal-  
544 organic framework based adsorption system for automotive air conditioning," *Appl.*  
545 *Therm. Eng.*, vol. 106, pp. 325–333, 2016.

546