Reliability Model for a Static Var Compensator

Alvarez Alvarado, Manuel; Jayaweera, Dilan

DOI:

[10.1109/ETCM.2017.8247445](https://doi.org/10.1109/ETCM.2017.8247445)

License:

Other (please specify with Rights Statement)

Document Version

Peer reviewed version

Citation for published version (Harvard):

Alvarez Alvarado, M & Jayaweera, D 2018, Reliability Model for a Static Var Compensator. in *2017 IEEE Ecuador Technical Chapters Meeting (ETCM)*. IEEE Xplore, IEEE Ecuador Technical Chapter Meeting (IEEE ETCM 2017), Ecuador, 16/10/17. <https://doi.org/10.1109/ETCM.2017.8247445>

[Link to publication on Research at Birmingham portal](#)

Publisher Rights Statement:

© 2017 IEEE. Personal use of this material is permitted. Permission from IEEE must be obtained for all other uses, in any current or future media, including reprinting/republishing this material for advertising or promotional purposes, creating new collective works, for resale or redistribution to servers or lists, or reuse of any copyrighted component of this work in other works.

General rights

Unless a licence is specified above, all rights (including copyright and moral rights) in this document are retained by the authors and/or the copyright holders. The express permission of the copyright holder must be obtained for any use of this material other than for purposes permitted by law.

- Users may freely distribute the URL that is used to identify this publication.
- Users may download and/or print one copy of the publication from the University of Birmingham research portal for the purpose of private study or non-commercial research.
- User may use extracts from the document in line with the concept of 'fair dealing' under the Copyright, Designs and Patents Act 1988 (?)
- Users may not further distribute the material nor use it for the purposes of commercial gain.

Where a licence is displayed above, please note the terms and conditions of the licence govern your use of this document.

When citing, please reference the published version.

Take down policy

While the University of Birmingham exercises care and attention in making items available there are rare occasions when an item has been uploaded in error or has been deemed to be commercially or otherwise sensitive.

If you believe that this is the case for this document, please contact UBIRA@lists.bham.ac.uk providing details and we will remove access to the work immediately and investigate.

Reliability Model for a Static Var Compensator

Manuel S. Alvarez-Alvarado

Department of Electronics, Electrical and Systems
Engineering
University of Birmingham
Birmingham, United Kingdom
manuel.alvarez.alvarado@ieee.org

Dilan Jayaweera

Department of Electronics, Electrical and Systems
Engineering
University of Birmingham
Birmingham, United Kingdom
d.jayaweera@bham.ac.uk

Abstract—This paper presents a reliability model of a Static Var Compensator (SVC) using an innovative algorithm based on sequential Monte Carlo simulation and Markov chains. The method employs the equivalent circuit of a SVC and takes the failure rate and repair time of each component as input in order to compute the failure rate and repair time of the whole SVC system. The specific contribution of this investigation is that it presents a mathematical pathway to model operating conditions of a SVC subject to individual operating states of its components, resulting in a comprehensive reliability model.

Keywords— *failure rate; Markov Chain; Monte Carlo simulation; reliability model; repair time; static var compensator*

I. INTRODUCTION

The Static Var Compensators (SVCs) are employed very often in power systems, due to its versatile and dynamic responses at the need of reactive power demand. Several studies related to its optimal operation and control have been proposed [1-3]. Nevertheless, its reliability is in fact not so far explored. Hence, there is a need to develop a model that characterizes its operational states.

The power systems possess different components and each of these are susceptible to failures. Some are more severe than others, for instance, lines have higher probabilities of failure than transformers as presented in the IEEE gold book [4]. This is defined by the component's failure rate (λ) and repair time (r).

The determination of the λ and r values for a system is not an easy task, since they required periodic operational records. These operational data can be transformed into statistical analysis in order to estimate λ and r values. Reference [5] presents an approach to evaluate the failure rate of a power transformer based on inspections. Reference [6] propose a methodology to calculate wind dependent failure rates for overhead transmission lines using reanalysis data records and a Bayesian updating scheme. Reference [7] employs a grey linear regression model with recorded operational data in order determine and predict the value of the failure rate of substation equipment. In the published literature, there is no comprehensive information related to λ and r values of a SVC, however, there are operational records of its components.

This paper proposes a new sequential Monte Carlo (MC) simulation that in combination with the Markov Chain, allows estimating the operational and failure states of a SVC. The paper has been organized as follows. Section II presents an extensive literature review related to the failure rates and repair hours of each component of the main circuit of a SVC. In section III, the theory related to the reliability models is presented. Section IV introduces the Markov chain as a pathway to develop a reliability model. Section V presents an advanced algorithm for a MC simulation applied to repairable components. In Section VI, the theories manifested in section III, IV and V are applied to develop the SVC main circuit reliability model. Finally, Section VII brings the conclusion based on the obtained results and the applied approach.

II. OPERATIONAL RECORDS OF THE COMPONENTS OF A STATIC VAR COMPENSATOR

The SVC has several functions such as control gain change, phase angle regulator, voltage support, power factor correction, loss reduction and more [8]. A SVC primarily has three systems: 1) Main circuit. 2) Auxiliary power supply; 3) Control and protection. This research focuses on the Main circuit which consists of thyristor controlled (TCR) and thyristor switched branches (TSC/TSR) together with filter branches for harmonic current absorption, medium voltage switchgear and the step down transformer. Fig. 1 shows a schematic diagram of the main circuit of a SVC.

In a reliability context, the more elements involved in a system the less reliability may get. Hence, applying this criterion to the SVC main circuit due to the number of components involved, the contribution of forced outages may be high. Nevertheless, these have lower failure rates. Moreover, the auxiliary power supply and the control and protection system contributes to failures more than the SVC main circuit, as presented in [9].

With a view to increasing the reliability in the system, the design for an SVC is presented in [10]. Furthermore, in [11] the authors state that a value for failure and repair rate of a SVC. Nevertheless, the reliability is limited to the TCR and TSC avoiding other elements that composite the main circuit of the SVC such as the harmonic filters, medium voltage switchgear and the step down transformer. A detailed description of the SVC main circuit is given below.

Fig. 1 Main Circuit SVC.

A. Thyristor Controlled Reactor

The composition of a TCR is basically, reactors with thyristor valves connected in series, as shown in Fig. 1. The failure rate for a reactor depends on their operating voltage. For instance, [12] reports a failure rate (failure/year) of 2×10^{-6} , for low voltage level. The TCR can operate with a medium voltage and for the case of forced outages with a reactor of this feature, [13] reports 0.0344 failures per year and repair time of 627.8 hours. For the thyristor valves, the authors in [14] reported between 0.00283 and 0.07299 failures per year. On the other hand, a repair time of 6.10 hours was reported in [15].

B. Thyristor Switched Capacitor

Unlike the TCR, the TSC includes capacitor banks as shown in Fig. 1 the failure rate for capacitors as the reactors depends on their operating voltage. In [16] states that distribution capacitor bank (medium voltage) has 0.17443 failures per year and a repair time of 2.30 hours. However, the values reported in [4, 13] for a shunt capacitor bank that works up to 109 kV is 0.0037 failures per year and 251.2 repair hours.

C. Harmonics Filters

They are generally divided into two parallel banks in Y-Y connection with ungrounded neutrals tied together with internal fuses that protect the capacitor units and for the cooling system, it uses fans [17]. The data recorded in [12, 18] is 0.0438 failures per year and a repair time of 0.25 hours [18] for damages related to the capacitor and fans. There is no comprehensive information about the repair time for forced outages, nevertheless repair time can be varied from three to seven hours, based on the experiences reported by personal of PSEG [19].

D. Medium Voltage Switchgear

Their reliability depends on their location (indoor or outdoor); voltage level; and equipment sub-class, which can be insulated or bare. When switchgear is connected to a SVC, it is insulated due to the high voltage level of the switchgear and it is commonly placed indoor. IEEE gold book [4] and the Power Systems Reliability Subcommittee [20] reported that these switch gears have a 0.0017 failures per year and a 26.8 hours of repair time.

E. Step-down Transformer

From a data collection between 1960 and 1980, of 32 utilities from Germany, Austria, Swiss, France, United Kingdom, Spain, Denmark and Netherlands, it was reported that an average of 0.005 failure per years for transformer up to 500 kV [21] with a repair time between 173.2 and 308.9 hours [13, 22].

All the other components of a SVC follow an exponential distribution [4, 13]. However, the distribution of the transformer is different because it follows a two-parameter Weibull distribution [23]. Hence, the parameters needed to develop the reliability model are the shape parameter β and the scale parameter η . The authors in [24] presents a study, which shows the distribution function and from there the values can be calculated using $\beta = 2.8076$ and $\eta = 55.14$ for sub-transmission transformers (63/20 kV). On the other hand, a detailed reliability model for power transformers was proposed in [25, 26] and reported the values of $\beta = 5$ and $50 \leq \eta \leq 80$. Reference [26] states that changing the value η does not affect the shape of the function of the instantaneous failure rate versus age, hence β is the predominant parameter in the distribution function.

III. RELIABILITY MODEL

The reliability model is based on operational records. This means, that when a failure occurs, all data related with it is recorded and then some analyses are done in order to get: 1. reliability index; 2. probabilistic models. Based on these, some preventive measure can be taken into account. Even a past behavior of a component can be gotten from a probabilistic model. In addition, a historical evaluation can be done with a reliability index. Hence, operational records allow performing reliability analysis with a view to finding the operational state for components in the past or future. An illustrative explanation is given in Fig. 2.

Most of the probabilistic models focus on determining the reliability, maintainability and availability function of a system. The reliability $R(t)$ is the probability of a system performing its intended function under stated conditions without failure for a given period of time. If the time to failure is defined by T , then the reliability can be mathematically expressed as [27]:

$$R(t) = P(t > T); t \geq 0 \quad (1)$$

Fig. 2 Reliability models based on time t .

Using the probability density function $f(t)$ (time to failure), the reliability can be written as [27]:

$$R(t) = \int_T^\infty f(t) dt \quad (2)$$

On the other hand, maintainability $M(t)$ is the probability of performing a successful repair action within a given time τ . Mathematically can be expressed as follows:

$$M(t) = P(0 < t < \tau) \quad (3)$$

The maintainability in terms of the renewal density function $g(t)$ (repair time) can be written as [27]:

$$M(t) = \int_0^\tau g(t) dt \quad (4)$$

The combination of high reliability and high maintainability lead to high system availability. The term availability is typically measured as a factor of reliability. The availability is very similar to the reliability function in that it gives a probability that a system will function at the given time, t . Unlike reliability, however, the instantaneous availability measure incorporates maintainability information. At a given time, t , the system will be operational if one of the following conditions is met [28]: 1. The system functioned properly from 0 to t . This means the probability of the event happening is $R(t)$; 2. The system was working properly since the last repair at time u , such that $0 < u < \tau$. The probability of this condition is defined as $\int_0^\tau R(\tau - u) g(u) du$. Consequently, the availability can be expressed as:

$$A(t) = R(t) + \int_0^t R(t - u) g(u) du \quad (5)$$

IV. MARKOV CHAIN

The reliability models of some components are not easy to deal with, since the mathematical models may be complex to solve. Nevertheless, a simple way to model is by applying Markov chain, which is a representation of all possible states in a diagram connected between them by variables called transition rates given by the failure rate $\lambda(t)$ and the repair rate $\mu(t)$ (the repair rate is defined as the inverse of the repair time $r(t)$). For instance, Fig. 3 shows a transition state of a repairable component with two possible states: operational and failure.

With a view to representing the model, consider a time interval Δt , which is very small in such a way that the occurrence probability of more than one fault or repair is very small and therefore the occurrence of these events can be neglected. Then:

Probability of a failure in time t = probability of a failure in time $(t + \Delta t) = \lambda(t)\Delta t$

Probability of a repair in time t = probability of a repair in time $(t + \Delta t) = \mu(t)\Delta t$

The probability of being in the operational state after a time interval Δt is equal to the probability of being operative

Fig. 3 Operational states.

At time t and not having failed in Δt plus the probability of being failed at time t and having been repaired in Δt :

$$P_1(t + \Delta t) = P_1(t)[1 - \lambda(t)\Delta t] + P_2(t)[\mu(t)\Delta t] \quad (6)$$

On the other hand, the probability of being in the repair state (failed) after a time interval Δt is equal to the probability of being failed in t and not having been repaired in Δt plus the probability of being non-failed in t and having failed in Δt :

$$P_2(t + \Delta t) = P_2(t)[1 - \mu(t)\Delta t] + P_1(t)[\lambda(t)\Delta t] \quad (7)$$

Solving (6):

$$\begin{aligned} P_1(t + \Delta t) &= P_1(t) - \lambda(t)P_1(t)\Delta t + \mu(t)P_2(t)\Delta t \\ \frac{P_1(t + \Delta t) - P_1(t)}{\Delta t} \Big|_{\Delta t \rightarrow 0} &= -\lambda(t)P_1(t) + \mu(t)P_2(t) \\ \frac{dP_1(t)}{dt} &= -\lambda(t)P_1(t) + \mu(t)P_2(t) \end{aligned} \quad (8)$$

Solving (7):

$$\begin{aligned} P_2(t + \Delta t) &= P_2(t) - \mu(t)P_2(t)\Delta t + \lambda(t)P_1(t)\Delta t \\ \frac{P_2(t + \Delta t) - P_2(t)}{\Delta t} \Big|_{\Delta t \rightarrow 0} &= \lambda(t)P_1(t) - \mu(t)P_2(t) \\ \frac{dP_2(t)}{dt} &= \lambda(t)P_1(t) - \mu(t)P_2(t) \end{aligned} \quad (9)$$

Expressing (8) and (9) in matrix form:

$$\begin{pmatrix} \frac{dP_1(t)}{dt} \\ \frac{dP_2(t)}{dt} \end{pmatrix} = \begin{pmatrix} -\lambda(t) & \mu(t) \\ \lambda(t) & -\mu(t) \end{pmatrix} \begin{pmatrix} P_1(t) \\ P_2(t) \end{pmatrix} \quad (10)$$

where $\dot{P}(t)$ is the time derivatives vector of the probabilities of each of the states, $\overline{P}(t)$ the probabilities vector of each of the states and H the stochastic matrix of transition states. Then, (10) can be written as:

$$\dot{P}(t) = H \overline{P}(t) \quad (11)$$

Applying Laplace transform:

$$s\overline{P}(s) - \overline{P}(0) = H \overline{P}(s) \quad (12)$$

$$\overline{P}(s) = \frac{\overline{P}(0)}{s - H} \quad (13)$$

Applying inverse Laplace transform:

$$\overline{P}(t) = \overline{P}(0)e^{Ht} \quad (14)$$

The solution for the system still being complicated due the exponential matrix involved. To simplify the solution, the Putzer's spectral formula is applied [29], in which the term e^{-Ht} can be expressed as a function of the eigenvalues v_i and eigenvectors $\bar{v}_i$ of the stochastic matrix of transition states H , as follows:

$$e^{Ht} = \sum_{i=1}^n \bar{v}_i e^{v_i t} \quad (15)$$

Replacing (15) in (14) and knowing that the $\overline{P(0)}$ will bring a constant C_i for each term of the sum, the general solution for the Markov chain is given by:

$$\overline{P(t)} = \sum_{i=1}^n C_i \bar{v}_i e^{v_i t} \quad (16)$$

Finally, the availability of the system can be calculated as the probability of all states that are in the set of operational states of the system defined in ϕ .

$$A(t) = \sum_{k \in \phi} P_k(t) \quad (17)$$

V. MONTE CARLO SIMULATION

Monte Carlo method is a broad class of a computational algorithm that relies on repeated random sampling to obtain numerical results [30, 31]. The method allows to: (1) obtain a solution of complicated or impossible mathematical models; (2) develop experiments that are not possible to do it directly due time involved, which can be very long; (3) get observations (data) of a random variable or process.

Sometimes it is not possible to get the reliability function of a system by employing analytical methods. This is due to the mathematical complexity involved as presented in section III. However, by employing MC simulation, the solution can be gotten.

In order to estimate the failure and repair rate of a system, an improved MC simulation architecture is employed. It uses the reliability parameters of each component as input data. The algorithm is divided into two parts, one to get the reliability function and the other to obtain the maintainability function of the system. The random number generation is done based on the failure rate and repair rate of each independent component. When all components are operating, the reliability is considered to be one, otherwise is zero. For the case of maintainability, it is considered as a success only if the generated number (time to repair) of all components, is less than the maximum time for restoration. Then, the values are saved and the experiment is repeated several times for each time slot defined. Finally, the mean value of the reliability and maintainability for each hour is gotten. For more details about the process, Fig. 4 presents the complete algorithm.

The developed algorithm has the pathways to scale down a complex problem to a manageable level with the aim of reducing the processing time and mathematical burden in comparison with the conventional MC simulation.

Fig. 4 Advanced Monte Carlo simulation algorithm for repairable components

VI. STATIC VAR COMPENSATOR RELIABILITY MODEL

The SVC that is used to incorporate in this study has the features shown in TABLE I.

TABLE I. DATA FOR SVC RELIABILITY ASSESMENT

	λ [failure per year]	r [repair hours]
Reactor air core	0.0344	628.1
Thyristor valve	0.0050	6.10
Capacitor bank	0.0037	251.2
Harmonic filters	0.0438	7.00
Switchgear	0.0017	26.8
Step down transformer	0.0050	200
	η [year]	β
Step down transformer	0.0344	5

A. SVC Reliability parameters

There is no data recorded about the λ and μ values for the TCR and TSC, hence they are to be estimated. MC simulation is applied by following the algorithm shown in Fig. 4. The input data for the simulation are the recorded data of the capacitor, reactor and thyristor valve of TABLE I. The results are shown in TABLE II.

TABLE II. TCR AND TSC RELIABILITY PARAMETERS

	TCR	TSC
λ [failure per year]	0.0599	0.0361
r [hours repair]	833.33	662.25

Now, combining all components of the SVC main circuit and employing again the developed MC algorithm, the reliability parameters of the SVC are gotten. This is presented in TABLE III.

TABLE III. SVC RELIABILITY PARAMETERS

	λ [failure per year]	r [hours repair]	μ [repair per year]
SVC	0.0906	1802	4.861

Finally, the algorithm allows describing the reliability of the SVC as a function of time. This is shown in Fig. 5.

B. SVC Operational States

The results in Fig. 5 reveal that the SVC reliability model follows an exponential distribution function, then the failure rate (λ) and repair rate (μ) becomes time-independent variables.

Now, the stochastic matrix of transition states is as follows:

$$H = \begin{pmatrix} -\lambda & \mu \\ \lambda & -\mu \end{pmatrix} \quad (18)$$

Later, the eigenvalues and eigenvectors are as follows respectively:

$$v_1 = 0; v_2 = -\lambda - \mu \quad (19)$$

$$\bar{v}_1 = \begin{pmatrix} \mu/\lambda \\ 1 \end{pmatrix}; \bar{v}_2 = \begin{pmatrix} -1 \\ 1 \end{pmatrix}; \quad (20)$$

Knowing that at $t = 0$ the component is in operational state ($P_1|_{t=0} = 1; P_2|_{t=0} = 0$), then (16) can written as:

$$\begin{pmatrix} 1 \\ 0 \end{pmatrix} = C_1 \begin{pmatrix} \mu/\lambda \\ 1 \end{pmatrix} e^{(0)(0)} + C_2 \begin{pmatrix} -1 \\ 1 \end{pmatrix} e^{(-\lambda-\mu)(0)} \quad (21)$$

Solving for C_1 and C_2 :

$$C_1 = \frac{\lambda}{\mu + \lambda}; C_2 = -\frac{\lambda}{\mu + \lambda} \quad (22)$$

Finally, the solution of a Markov chain for a repairable component that follows an exponential distribution function with two operational states is:

Fig. 5 Reliability function for a SVC

$$P_1(t) = \frac{\mu}{\mu + \lambda} + \frac{\lambda}{\lambda + \mu} e^{-(\lambda+\mu)t} \quad (23)$$

$$P_2(t) = \frac{\lambda}{\mu + \lambda} - \frac{\lambda}{\lambda + \mu} e^{-(\lambda+\mu)t} \quad (24)$$

Replacing λ and μ values given in TABLE III, the probabilities of operational and failure state for a SVC is respectively:

$$P_1(t) = 0.9817 + 0.0183e^{-4.9096t} \quad (25)$$

$$P_2(t) = 0.0183 - 0.0183e^{-4.9096t} \quad (26)$$

The state “1” defines the availability of the SVC, while the state “2” defines its unavailability.

VII. CONCLUSIONS

This paper proposes a systematic methodology for modelling and quantification of the reliability for a SVC. The advanced MC simulation proposed in this paper allows determining the reliability parameters of a SVC system based on the operational records of components that are integrated into the SVC.

A general solution for Markov chains is presented and employed to describe the availability and unavailability of a SVC. The methodology can also be extended to the other FACTS devices.

The proposed approach presents a technical pathway for assessing the reliability performance of a SVC integrated in a power grid.

ACKNOWLEDGMENT

This study was supported by the Walter Raffo Valdano II program in Escuela Superior Politécnica del Litoral (ESPOL) and the Secretariat of Higher Education, Science, Technology and Innovation of the Republic of Ecuador (Senescyt).

REFERENCES

- [1] S. Wang, S. Chen, L. Ge, and L. Wu, "Distributed Generation Hosting Capacity Evaluation for Distribution Systems Considering the Robust Optimal Operation of OLTC and SVC," *IEEE Transactions on Sustainable Energy*, vol. 7, pp. 1111-1123, 2016.
- [2] T. Masood, R. K. Aggarwal, S. A. Qureshi, and R. A. J. Khan, "STATCOM and SVC control operations and optimization during network fault conditions," in *2010 IEEE International Symposium on Industrial Electronics*, 2010, pp. 1088-1091.
- [3] D. B. Kulkarni and G. R. Udupi, "Optimized operation of SVC for minimal harmonics at distribution level," in *2007 IET-UK International Conference on Information and Communication Technology in Electrical Sciences (ICTES 2007)*, 2007, pp. 469-474.
- [4] "IEEE Recommended Practice for the Design of Reliable Industrial and Commercial Power Systems (Gold Book)," *IEEE Std 493-1997 [IEEE Gold Book]*, pp. 1-464, 1998.
- [5] E. Abbasi and O. P. Malik, "Failure rate estimation of power transformers using inspection data," in *Probabilistic Methods Applied to Power Systems (PMAPS), 2016 International Conference on*, 2016, pp. 1-4.
- [6] Ø. R. Solheim and G. Kj, "Wind dependent failure rates for overhead transmission lines using reanalysis data and a Bayesian updating scheme," in *Probabilistic Methods Applied to Power Systems (PMAPS), 2016 International Conference on*, 2016, pp. 1-7.
- [7] G. Tianshan and G. Bo, "Failure rate prediction of substation equipment combined with grey linear regression combination model," in *High Voltage Engineering and Application (ICHVE), 2016 IEEE International Conference on*, 2016, pp. 1-5.
- [8] M. Mahdavian, G. Shahgholian, P. Shafaghi, M. Azadeh, S. Farazpey, and M. Janghorbani, "Power system oscillations improvement by using static VAR compensator," in *Electrical Engineering/Electronics, Computer, Telecommunications and Information Technology (ECTI-CON), 2016 13th International Conference on*, 2016, pp. 1-5.
- [9] A. Janke, J. Mouatt, R. Sharp, H. Bilodeau, B. Nilsson, M. Halonen, et al., "SVC operation & reliability experiences," in *Power and Energy Society General Meeting, 2010 IEEE*, 2010, pp. 1-8.
- [10] A. Bostrom and B. Mehraban, "Design and application of SVC units in the Texas CREZ system," in *2014 IEEE PES T&D Conference and Exposition*, 2014, pp. 1-8.
- [11] G. M. Huang and Y. Li, "Composite power system reliability evaluation for systems with SVC and TCPAR," in *2003 IEEE Power Engineering Society General Meeting (IEEE Cat. No.03CH37491)*, 2003, pp. 1-776 Vol. 2.
- [12] S. Kaboli, *Reliability in Power Electronics and Electrical Machines: Industrial Applications and Performance Models: Industrial Applications and Performance Models*: IGI Global, 2016.
- [13] D. O. Koval, "Transmission equipment reliability data from Canadian electrical association," *IEEE Transactions on Industry Applications*, vol. 32, pp. 1431-1439, 1996.
- [14] H. Stomberg, B. Abrahamsson, and O. Saksvik, "Modern HVDC thyristor valves," *ICEE 96, Beijing China*, 1996.
- [15] T.-M. Bajenescu and M. I. Bazu, *Reliability of electronic components: a practical guide to electronic systems manufacturing*: Springer Science & Business Media, 2012.
- [16] P. Hale and R. G. Arno, "Survey of reliability and availability information for power distribution, power generation, and HVAC components for commercial, industrial, and utility installations," in *Industrial and Commercial Power Systems Technical Conference, 2000. Conference Record. Papers Presented at the 2000 Annual Meeting. 2000 IEEE*, 2000, pp. 31-54.
- [17] A. Kusko and M. T. Thompson, *Power quality in electrical systems*: McGraw-Hill, 2007.
- [18] Schaffner. (2014). *Installation Manual Passive Harmonic Filters*. Available: http://www.schaffner.com/fileadmin/media/downloads/Installation_Manual/Schaffner_IM_ECOSine_Full_Performance_Line.pdf
- [19] D. Agudelo, "Interview related with SVC reliability," ed, 2016.
- [20] P. O'Donnell, "Report of Switchgear Bus Reliability Survey of Industrial Plants and Commercial Buildings," *IEEE Transactions on Industry Applications*, pp. 141-147, 1979.
- [21] F. Vahidi and S. Tenbohlen, "Statistical failure analysis of European substation transformers," *ETG-Fachbericht-Diagnostik elektrischer Betriebsmittel 2014*, 2014.
- [22] F. Roos and S. Lindah, "Distribution system component failure rates and repair times—an overview," in *Conf. Rec. the Nordic Distribution and Asset Management Conference*, 2004.
- [23] W. Li, "Evaluating mean life of power system equipment with limited end-of-life failure data," *IEEE Transactions on Power Systems*, vol. 19, pp. 236-242, 2004.
- [24] M. Mirzai, A. Gholami, and F. Aminifar, "Regular paper Failures Analysis and Reliability Calculation for Power Transformers," *J. Electrical Systems*, vol. 2, pp. 1-12, 2006.
- [25] R. Jongen, E. Golski, P. Morshuis, J. Smit, and A. Janssen, "Statistical analysis of power transformer component life time data," in *2007 International Power Engineering Conference (IPEC 2007)*, 2007, pp. 1273-1277.
- [26] D. Zhou, Z. Wang, and C. Li, "Data Requisites for Transformer Statistical Lifetime Modelling—Part I: Aging-Related Failures," *IEEE Transactions on Power Delivery*, vol. 28, pp. 1750-1757, 2013.
- [27] H. Pham, "System Reliability Concepts," in *System Software Reliability*, ed London: Springer London, 2006, pp. 9-75.
- [28] E. Elsayed, "Reliability Engineering (AddisonWesley Longman, Inc., Reading, MA)," 1996.
- [29] R. Agapito, "Cálculo exacto de la matriz exponencial," *Pro Mathematica*, vol. 28, pp. 57-84, 2014.
- [30] R. N. Allan, *Reliability evaluation of power systems*: Springer Science & Business Media, 2013.
- [31] W. Li, *Reliability assessment of electric power systems using Monte Carlo methods*: Springer Science & Business Media, 2013.